



Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF ASSESSMENT</b>	<b>CERTIFICATE No : SFC 27615-02A</b>	<b>Page 1 of 1</b>
---------------------------------------	---------------------------------------	--------------------



Report Sponsor	Certificate Issue Date	Product Name
Dulux AcraTex 1956 Dandenong Road Clayton VIC 3168	19/05/2015	Dulux Exsulte Façade System

Referenced Report	Referenced Standard	Report Issue Date	Report Validity Date
EWFA 27615-02	AS 1530.8.1- 2007	19/05/2015	31/10/2017

Introduction
The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for a complete description of the assessed construction.

Assessed Framed Wall system description and performance
Exsulte Cavity Wall System Description
<p>Wall system consisting of timber framing at least 70mm deep or light gauge steel framing at least 90mm deep. Unexposed side faced with 10mm Gyprock plasterboard.</p> <p>Exposed side with a minimum of 4.0mm Dulux® Exsulte Matrix as a basecoat with a further 1.5mm coat of Dulux® Exsulte Acrylic Texture Coat and Dulux Exsulte Membrane Topcoat applied over the following Dulux Exsulte Substrate Systems;</p> <ul style="list-style-type: none"> <li>75mm Dulux Exsulte panel over 25mm EPS spacer,</li> <li>60mm Dulux Exsulte panel over 15mm EPS spacer,</li> <li>100mm Dulux Exsulte panel over 40mm EPS spacer.</li> </ul> <p>R2 insulation batt is optionally included within the wall cavity</p> <p>Refer the referenced report for a complete description of the assessed construction.</p>
<b>BAL</b>
<b>BAL A-29</b>

Conditions/Validity
<ul style="list-style-type: none"> <li>THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.</li> <li>Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.</li> <li>The assessment report or short form assessment report does not provide an endorsement by Exova Warringtonfire Aus Pty Ltd of the performance of the actual products supplied. It is intended to provide a brief outline of the above referenced assessment reports and not to replace them.</li> <li>The conclusions in this certificate of assessment relate to the configurations as detailed, and should not be applied to any other configuration. The conclusions expressed in this document assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.</li> <li>Full copies of the assessment and relevant test reports may be obtained from the sponsor.</li> </ul>

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd
Address	Suite 2002a, Level 20, 44 Market Street, Sydney NSW 2000, Australia
Phone / Fax	+61 (0)2 8270 7600 / +61 (0)2 9299 6076
ABN	81 050 241 524
Email / Home Page	<a href="http://www.exova.com">www.exova.com</a>
Authorisation	<p>Prepared By:  S. Hu</p> <p>Reviewed By:  K. G. Nicholls</p>